



Final Acceptance (FA) Punchlist
EPC - DPW - Stormwater Section

Project Name:	Super Star Car Wash
EDARP Filing Number(s):	PPR218
ESQCP Number:	ESQ2211
Attendees:	DPW SW: Erica Rylander DPW Planning: Brad Walters, David Parkerson Developer: Matt Horton
Date of Walk-Thru:	3/20/2023
Walk-Thru Number:	1 st

Please have all items completed within six months of the date on this punchlist. If all items are not completed within six months, a new punchlist will be created. When all items are completed, please let your inspector know as soon as possible so they can come out to the project to confirm.

Findings to be addressed prior to scheduling a follow-up walk-thru:

- Remove straw wattles from south side of building.
- Re-install erosion control blanket on slope on south side of building per detail.
- Implement final stabilization measures (i.e. seed and hydromulch/straw mulch) in areas south of site that were disturbed during vertical construction.

Photos:



Photo 1: On south side of building: remove straw wattles and re-install erosion control blanket per detail.



Photo 2: Implement final stabilization measures throughout bottom of pond in areas disturbed during vertical construction.




Photo 3: Implement final stabilization measures at southwest corner of site in areas disturbed during vertical construction.