

FEDERAL AVIATION ADMINISTRATION INFORMATION



FEDERAL AVIATION ADMINISTRATION INFORMATION

provide
correspondence from
FAA; this is not
correspondence

Xcel Energy understands that El Paso County requires a Determination of No Hazard from the Federal Aviation Administration (FAA). The new 345-kV double circuit transmission line will be constructed using steel poles between 105-140 feet above ground level, and poles will not exceed 199-foot maximum height (see Section 1.4.a of the 1041 Application Narrative for additional information). Xcel Energy will use the FAA hazard tool to determine any structures that require review by the FAA. Xcel Energy will file FAA Form 7460-1, Notice of Proposed Construction or Alteration, with the FAA following final design for any structures that require FAA review.