



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

### **McDaniels Rezone, P-22-6**

**Please accept the following comments from El Paso County Public Health (EPCPH) regarding the 40-acre, 4-residential lot project referenced above:**

- **There are no public health issues noted with the proposed rezone noted by El Paso County Public Health.**
- **Each lot developed must have an approved Onsite Wastewater Treatment System (OWTS) Permit issued prior to lot development. All minimum horizontal OWTS installation setbacks must be met.**
- **The 2021 water quality report referenced in the Letter of Intent was not included in the submittal; therefore, a finding for sufficiency was not made at this time, nor is it required at this point.**

**Mike McCarthy**  
**El Paso County Public Health**  
**[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)**  
**719-332-5771**  
**11June2022**